



- ELECTRICAL CONTRACTOR TO PROVIDE**
- ALL CONDUIT AS DETAILED
 - 117 VAC SERVICE, 30 AMP SERVICE TO EACH CUSTOMER UNIT (20 AMP FULL LOAD)
 - CONDUIT 'C' IS FOR LOW VOLTAGE CONTROL CABLES INSTALLED BY TUBE SUPPLIER
 - ELECTRICAL CONTRACTOR TO PROVIDE PULL WIRES IN EACH CONDUIT

HAMILTON AIR

MODEL HA-47
 UPSEND CUSTOMER UNIT

REVISION '1'
 Drawing Number : 99-852 Date : 7-1-03

LEFT SIDE ELEVATION

FRONT ELEVATION

UNDERGROUND CONDUIT ENTRY (CUSTOMER SIDE)

CONDUIT DETAIL
 3 SYSTEMS SHOWN